

# Display energy certificate (DEC)

STAR MAT  
MAIN BUILDING  
Monk Fryston C of E Primary School  
Chestnut Green  
Monk Fryston  
LEEDS  
LS25 5PN

Operational rating

**E**

Certificate number: 2623-1776-2026-5302-4421

Valid until: 29 June 2023

Total useful floor area: 1012.24 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>		
51-75	<b>C</b>		
76-100	<b>D</b>		
			100 ..
101-125	<b>E</b>	<b>125   E</b>	
126-150	<b>F</b>		
150+	<b>G</b>		

## Previous operational ratings

Date	Operational rating
June 2022	<b>125   E</b>
June 2021	<b>105   E</b>
June 2020	<b>115   E</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
June 2022	34	33	0
June 2021	29	28	0
June 2020	33	29	0

## Assessment details

Assessor's name	Dr. Steffi Harangozo
Employer/Trading name	North Yorkshire County Council
Employer/Trading address	County Hall, 1 Racecourse Lane, Northallerton, DL7 8AL
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	24 June 2022
Nominated date	30 June 2022

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	61.33	166.55
Typical energy use (kWh/m <sup>2</sup> /year)	41.23	155.07
Energy from renewables	0%	0%

